





Certificate of Analysis

Product: **R134a**
Batch No: 20190624001
Product Date: 2019.6.24

Standard: AHRI 700-2017
Source of Sample: Cylinder
Inspection Date: 2019.6.24

Inspection Items	AHRI 700-2017	Results
Product Appearance	Visually clean	Pass
Particulates/solids	Visually clean	Pass
Purity	99.50%	99.94%
Moisture, Maximum	10ppm	9ppm
Acidity, Maximum (as HCL)	1ppm	0.1ppm
Chloride, Maximum	No visible turbidity	Pass
Evaporating residue, Maximum	0.01%	0.0006%
Non-condensable gas, Maximum	1.50%	0.94%
Halogenated unsaturated hydrocarbon, Maximum	No Standard	0.0008%
Conclusion: Superior grade, confirmed as per AHRI 700-2017 standard.		
 		
Remark:		

FREEZE REFRIGERANTS

Corporate Office: #05-01, Grand Building,
Grand Building, 17 Phillip Street, Singapore 048695
Email: sales@freezeref.com Web: www.freezeref.com