





Certificate of Analysis

Product: **R404A**
 Batch No: R404A190624009
 Product Date: 2019.6.24

Standard: AHRI 700-2017
 Source of Sample: Cylinder
 Inspection Date: 2019.6.24

Inspection Items	AHRI 700-2017	Results
R125	42.0 - 46.0%	44.40%
R143a	51.0 - 53.0%	52.45%
R134a	2.0 - 6.0%	3.15%
Product Appearance	Visually clean	Pass
Particulates/solids	Visually clean	Pass
Purity	99.50%	99.95%
Moisture, Maximum	10ppm	8ppm
Acidity, Maximum (as HCL)	1ppm	<0.1ppm
Chloride, Maximum	No visible turbidity	Pass
Evaporating residue, Maximum	0.01%	<0.01%
Conclusion: Superior grade, confirmed as per AHRI 700-2017 standard. <div style="display: flex; justify-content: space-around; align-items: center;">   </div>		
Remark:		

FREEZE REFRIGERANTS

Corporate Office: #05-01, Grand Building,
 Grand Building, 17 Phillip Street, Singapore 048695
 Email: sales@freezeref.com Web: www.freezeref.com