





Certificate of Analysis

Product: **R407C**
 Batch No: R407C190624005
 Product Date: 2019.6.24

Standard: AHRI 700-2017
 Source of Sample: Cylinder
 Inspection Date: 2019.6.24

Inspection Items	AHRI 700-2017	Results
R32	21.0 – 25.0%	23.03%
R125	23.0 – 27.0%	25.40%
R134a	50.0 – 54.0%	51.57%
Product Appearance	Visually clean	Pass
Particulates/solids	Visually clean	Pass
Purity	99.50%	99.95%
Moisture, Maximum	10ppm	9ppm
Acidity, Maximum (as HCL)	1ppm	≤0.1ppm
Chloride, Maximum	No visible turbidity	Pass
Evaporating residue, Maximum	0.01%	≤0.01%
Conclusion: Superior grade, confirmed as per AHRI 700-2017 standard. <div style="display: flex; justify-content: space-around; align-items: center; margin-top: 10px;">   </div>		
Remark:		

FREEZE REFRIGERANTS

Corporate Office: #05-01, Grand Building,
 Grand Building, 17 Phillip Street, Singapore 048695
 Email: sales@freezeref.com Web: www.freezeref.com