





Certificate of Analysis

Product : R417A
Batch No: R41701012021
Product Date : 2020.12.1

Standard: AHRI 700-2017
Source of Sample: Cylinder
Inspection Date: 15.01.2021

Inspection Items	AHRI 700-2017	Results
R125	45.5 - 47.7%	46.08%
R600	3.0 - 3.5%	3.36%
R134a	49.0 - 51.0%	50.56%
Product Appearance	Visually clean	Pass
Particulates/solids	Visually clean	Pass
Purity	99.50%	99.90%
Moisture, Maximum	10ppm	8ppm
Acidity, Maximum (as HCL)	1ppm	<0.1ppm
Chloride, Maximum	No visible turbidity	Pass
Evaporating residue, Maximum	0.01%	<0.01%
Conclusion: Superior grade, confirmed as per AHRI 700-2017 standard.		
 		
Remark:		

FREEZE REFRIGERANTS

Corporate Office: #05-01, Grand Building,
Grand Building, 17 Phillip Street, Singapore 048695
Email: sales@freezeref.com Web: www.freezeref.com