

Certificate of Analysis

Product: R1270 Standard: AHRI 700-2017 Batch No: R127001012021 Source of Sample: Cylinder

Product Date: 2020.12.1 Inspection Date: 15.01.2021

Inspection Items	AHRI 700-2017	Results
Product Appearance	Visually clean	Pass
Particulates/solids	Visually clean	Pass
Smell	No Sulfur Odor	Pass
Purity	99.5%	99.52%
Moisture, Maximum	10ppm	8ppm

Conclusion: Superior grade, confirmed as per AHRI 700-2017 standard.



Remark: