





## Certificate of Analysis

Product : R407C  
Batch No: R29001012021  
Product Date : 2020.12.1

Standard: AHRI 700-2017  
Source of Sample: Cylinder  
Inspection Date: 15.01.2021

Inspection Items	AHRI 700-2017	Results
R32	21.0 - 25.0%	23.03%
R125	23.0 - 27.0%	25.40%
R134a	50.0 - 54.0%	51.57%
Product Appearance	Visually clean	Pass
Particulates/solids	Visually clean	Pass
Purity	99.50%	99.95%
Moisture, Maximum	10ppm	9ppm
Acidity, Maximum (as HCL)	1ppm	≤0.1ppm
Chloride, Maximum	No visible turbidity	Pass
Evaporating residue, Maximum	0.01%	≤0.01%
Conclusion: Superior grade, confirmed as per AHRI 700-2017 standard.		
 		
Remark:		

### FREEZE REFRIGERANTS

Corporate Office: #05-01, Grand Building,  
Grand Building, 17 Phillip Street, Singapore 048695  
Email: sales@freezeref.com Web: www.freezeref.com